CeBE Centre for the Built Environment

leeds metropolitan university

24th April 2013, Croke Park, Dublin

BetterBuilding

International Conference for a Sustainable Built Environment

Sponsored by ECOCEM

IN ASSOCIATION WITH eu2013.ie

Closing the Performance Gap: Beyond Stamford Brook

Dominic Miles-Shenton

David Johnston, Jez Wingfield, David Farmer, Malcolm Bell

Closing the Performance Gap: Beyond Stamford Brook

Evidence of a Fabric Performance Gap?
How can it be Measured?
Regulatory Implications – so far…
Performance Gap for Retrofit
Closing the Loop
Simple Tests (do try this at home!)

Evidence for a fabric Performance Gap



- **The performance of the building fabric performance is very rarely understood and often taken for granted.**
- **Heat loss is often much higher than calculated during design.**
- **Highly dependent upon the design and installation of the insulation layers (Hens et al., 2007 and Doran, 2000).**

Measuring the Performance Gap



Construction observations

Pressurisation testing

Tracer gas measurement

Coheating test

Cavity temperature measurement

Heat flux measurement

Leakage detection




Air flow measurements

Partial deconstruction

Thermal imaging



Coheating Testing

- **It is NOT a new concept, although it is in its infancy.**
- **Developed in the USA (LBL) in the late 1970's in response to the energy crisis (see Sonderegger et al. 1979).**
- **Used in a small number of occasions in the UK in the 1980's.**
- **Re-invented by Leeds Met at Stamford Brook 2005/6**



Siviour Analysis:
(solar/ΔT) vs. (power/ΔT)
Heat Loss = y intercept
Solar Aperture = slope

Coheating Testing





Party wall bypass investigations – Stamford Brook

Party wall bypass investigations – Stamford Brook

Mid Terrace



Type	Predicted Fabric Heat Loss (W/K)	Predicted Ventilation Heat Loss (W/K)	Predicted Total Heat Loss (W/K)	Measured Heat Loss (W/K)	Measured Heat Loss - Adjusted for Solar Gain (W/K)
				+75%	
Semi	50.6	13.2	63.8	105.4	111.7
Mid Terrace	54.9	20.3	75.2	136.3	153.4
				+104%	

Party wall bypass investigations – Stamford Brook



Party wall bypass investigations – Stamford Brook



Party wall bypass investigations – Stamford Brook

Party wall bypass investigations – Stamford Brook



Loft Party Wall Sock in

Remove Sock



Loft Party Wall Sock out

Party wall bypass investigations – Stamford Brook



Second Floor – Party Wall to External Wall Junction – Sock Out

Party wall bypass investigations – Stamford Brook

Party Wall Junction – Sock in Position



Party Wall Junction – Sock Removed



Party Wall Junction – Brick at Hot Spot Removed



Party wall bypass investigations – Stamford Brook



Party wall bypass investigations – Stamford Brook



Mean Heat Loss Coefficient:	With Sock	10.7 W/K
	Without Sock	37.9 W/K
Effective Party Wall *U*-value:	With Sock	0.18 W/m^{2}K
	Without Sock	0.63 W/m^{2}K

Party wall bypass investigations – Stamford Brook

Party Wall Max Air Flow – B116-117 – Sock In



Party Wall Max Air Flow – B116-117 – Sock Out



Party wall bypass investigations – Stamford Brook

Cold Air Infiltration Paths

Heat Loss Paths



Party wall bypass investigations – Stamford Brook

Party Wall Bypass – Estimated UK CO_2 savings if bypass eliminated

From New Housing built in One Year (~190,000 units)	18,000 tCO_2/a
From Existing Stock (built since 1965)	~750,000 tCO_2/a

Assumes Party Wall *U*=Value = 0.5 W/m^2K
Assumes 10% semi-detached, 20% terrace in stock and new build
Calculations for semis and terraces only – no estimate for apartments



Party wall bypass investigations – EURISOL / MIMA

Party wall bypass investigations – EURISOL / MIMA





Party wall bypass investigations – EURISOL / MIMA





- Party wall cavity temperature
- Party wall surface temperature
- Internal/cavity differential pressure
- Heat flux
- Party wall cavity airflow - horizontal
- Party wall cavity airflow - vertical

Party wall bypass investigations – EURISOL / MIMA



Party wall bypass investigations – EURISOL / MIMA



- Material: Knauf Supafil Plus 40
- Usage: ~6 bags = 106kg over ~72.4m^2 (Cavity ~75mm)
- Estimated fill density: ~19.6 kg/m^3 (Volume ~ 5.4m^3)

Party wall bypass investigations – EURISOL / MIMA



Heat Loss Before Fill (W/K)	Heat Loss After Fill (W/K)	Heat Loss Improvement (W/K)
229.1	191.4	37.7 (-16%)

37.7 W/K ÷ 69 m^2 = 0.55 W/m^2K

Party wall bypass investigations – EURISOL / MIMA



Party wall bypass investigations – EURISOL / MIMA







Implications for Building Regulations

HM Government

Section 5: Quality of construction and commissioning

CRITERION 4 – BUILDING PERFORMANCE CONSISTENT WITH *DER*

Fully filling the cavity may have implications for sound transmission through party walls. Developers who follow this route must satisfy the BCB that the requirements of Part E will be satisfied, either by adopting a full fill detail accredited under

L1A QUALITY OF CONSTRUCTION AND COMMISSIONING

Table 3 U-values for party walls

Party wall construction	U-value (W/m^2K)
Solid	0.0
Unfilled cavity with no effective edge sealing	0.5
Unfilled cavity with effective sealing around all exposed edges and in line with insulation layers in abutting elements	0.2
A fully filled cavity with effective sealing at all exposed edges and in line with insulation layers in abutting elements	0.0

5.8 The party wall is a particular case of the more general thermal bypass problem that occurs where the air barrier and the insulation layer are not contiguous and the cavity between them is subject to air movement. To avoid the consequent reduction in thermal performance, either the insulation layer should be contiguous with the air barrier at all points in the building envelope, or the space between them should be filled with solid material such as in a masonry wall.

Thermal bridges

For new buildings, such scheme(s) accredit and quality assure the calculation of the linear thermal transmittance, accredit details in terms of buildability and have an associated quality assurance regime that inspects a sample of sites to confirm that the details are being implemented correctly. The use of such schemes may also allow a reduction in the Building Control charges.

b. To use details that have not been subject to independent assessment of the construction method. However, in this case, the linear thermal transmittance should still have been



Existing dwellings

2009/10: Temple Avenue Project, York

Project funded by the Joseph Rowntree Housing Trust

Thin-Joint Masonry & SIPs Construction
Code for Sustainable Homes Level 4
Prototypes for a 540-home development

Standard 1930's semi-detached property
2-stage refubishment:

1. Standard decent homes upgrade
2. Enhance energy performance to the same level as the prototypes

2009/10: Temple Avenue Project, York

Project funded by the Joseph Rowntree Housing Trust



Existing dwelling - TAP



GROUND FLOOR PLAN



FIRST FLOOR PLAN

Existing dwellings - TAP



Existing dwelling - TAP



Existing dwellings - TAP







Existing dwellings - TAP





Existing dwellings - TAP



Existing dwellings - TAP







Closing the Loop



Closing the Loop

Ventilation Heat Loss

Air Permeability ($m^3/(h.m^2)$ @ 50Pa)					Mean Permeability used for coheating calculations
Date	09-Nov-10	14-Jan-11	01-Feb-11	25-Feb-11	
Plot 6	9.28	3.85	4.31	4.48	4.395
	pre-completion	Building Regs compliance	pre-coheating	post-coheating	(5.15 h^{-1}@50Pa)

Ventilation Rate (h^{-1}, (Roulet & Foradini 2002))				Mean Wind Speed
Date	Bedroom 1	Lounge	Bedroom 3	
11 Feb	**0.31**	**0.32**	**0.31**	**1.02**
12 Feb	**0.29**	**0.31**	**0.30**	**1.75**
13 Feb	**0.35**	**0.38**	**0.35**	**2.64**
19 Feb	**0.35**	**0.34**	**0.34**	**1.74**
20 Feb	**0.35**	**0.37**	**0.34**	**2.04**

Closing the Loop

External Wall Measurements



Closing the Loop

External Wall Measurements

4 5
3
1 2



Closing the Loop



64% greater heat loss than predicted

Closing the Loop

Thermal Bridging





Closing the Loop

Thermal Bridging

Therm 5.2 model: 300mm Hemcrete (λ= 0.06 W/mK), 89mm Timber stud (λ = 0.13 W/mK), 400mm Loft insulation (λ = 0.042 W/mK)



Ψ= 0.026 W/mK
45º Pitch



Ψ= 0.043 W/mK
30º Pitch



Ψ= 0.084 W/mK
'as-built' - ideal



Ψ= 0.109 W/mK
'as-built' - practice

SAP 2009, Appendix Q, Table K1 :

Eaves detail to ACD — Ψ = 0.06 W/mK
Default value — Ψ = 0.12 W/mK

Closing the Loop

Designed HLC 134.9 W/K - Measured HLC 220.6 W/K



Simple Tests

Simple Tests



Simple Test Issues: Thermal Lag

Maximum ΔT

Maximum Heat Flux



CeBE Centre for the Built Environment

leeds metropolitan university

Whole House Heat Loss Test Method (Coheating)

Dr David Johnston, Centre for the Built Environment, Leeds Metropolitan University
Dominic Miles-Shenton, Centre for the Built Environment, Leeds Metropolitan University
Dr Jez Wingfield, Willmott Dixon Energy Services Limited
David Farmer, Centre for the Built Environment, Leeds Metropolitan University
Prof Malcolm Bell, Centre for the Built Environment, Leeds Metropolitan University

March – 2012

http://www.leedsmet.ac.uk/as/cebe/index.htm

LEEDS METROPOLITAN UNIVERSITY
Leeds Sustainability Institute